



"Delivering Excellence"

July 13, 2020

Electrical Board Minutes – July 13, 2020

Call to Order: Travis Blankinship

Present: Rick Kiister, Dennis Royer, Travis Blankinship and Rick Howard, & David Cowan

Absent: Kenny Evans

Approval of Minutes: Review of the June 08, 2020 minutes.
Motion to approve Travis Second Rick H. Yes – 4 No - 0

Old Business: Reviewed the approved ordinance that was returned to the Board. Discussion about the 10' feet from the meter base. The distance from the meter to the breaker box greater than 10' requires a disconnect. The disconnect must be within 10' of the meter base. Distance from the disconnect to the breaker box is not regulated but NEC specifies wire type and how the wire is installed.

Item (4) – board removed the language that required the board approval.

Motion to approve change: Travis Second: Rick H. Yes – 4 No - 0

New Business: Discussion of Federal Pacific Panels but no action taken.


Motion to adjourn: Travis Blankinship Second: Rick Howard MSP.

Kenny Evans

8/10/2020

Kenny Evans, Chair

Date


David Cowan, Bldg Inspector/Secretary